



TENNESSEE

**JIM STRICKLAND  
MAYOR**

**DIVISION OF PARKS &  
NEIGHBORHOODS**

**Tennis Court Improvements for Frayser Tennis Center (Rebid)**  
CIP #PK03004

**Addendum No. 1**      June 21, 2023

**To All Bidders: The following changes and/or clarifications are hereby made to the Plans and Specifications:**

**Item #1 – Bid Reception Date** – The bid reception date is moved from 12:00 p.m. (noon) June 28, 2023 to 12:00 p.m. (noon) July 12, 2023.

**Item #2 – Specifications Section 01005 – Project Sign** – Temporary Job Sign Type A has been removed from the site by previous construction at the site. The posts for this job sign were broken at grade level with remnants of the posts still in the ground. For this project, in addition to the requirements of this specification section, the contractor will need to dig and remove the post remnants, and then supply a new Temporary Job Sign Type A per the detail in this Section 01005.

**Item #3 – Product Substitution Request:** Plexipave and DecoColor product lines by California Sports Surfaces are approved on this project **provided that the products meet the stated conditions** (see Addendum #1 Attachment #1).

**End of Addendum No. 1**

# ATTACHMENT #1

## SUBSTITUTION REQUEST (During the Bidding/Negotiating Stage)

Project: Tennis Court Improvements for Frayser Tennis Center Substitution Request Number: Spec-0049048  
Memphis, TN From: Paulette Hogan, ICP Building Solutions Group  
To: Keith Schnadelbach, City of Memphis Purchasing Agent Date: 01/20/2023  
keith.schnadelbach@memphistn.gov, 9016364248 A/E Project Number: \_\_\_\_\_  
Re: Tennis Court Color Coating System Contract For: City of Memphis Purchasing Agent

Specification Title: Tennis Court Color Coating System Description: Acrylic Tennis Court Color System  
Section: \_\_\_\_\_ Page: \_\_\_\_\_ Article/Paragraph: \_\_\_\_\_

Proposed Substitution: Plexipave, DecoColor  
Manufacturer: ICP Building Solutions Group Corporate HQ: 150 Dascomb RD. Andover, MA 01810 Phone: (800) 225-1141  
Trade Name: Plexipave, DecoColor Model No.: N/A

Attached data includes product description, specifications, drawings, photographs, and performance and test data adequate for evaluation of the request; applicable portions of the data are clearly identified.

Attached data also includes a description of changes to the Contract Documents that the proposed substitution will require for its proper installation.

### The Undersigned certifies:

- Proposed substitution has been fully investigated and determined to be equal or superior in all respects to specified product.
- Same warranty will be furnished for proposed substitution as for specified product.
- Same maintenance service and source of replacement parts, as applicable, is available.
- Proposed substitution will have no adverse effect on other trades and will not affect or delay progress schedule.
- Proposed substitution does not affect dimensions and functional clearances.

Submitted by: Paulette Hogan  
Signed by: Paulette Hogan  
Firm: ICP Building Solutions Group  
Address: \_\_\_\_\_  
, MA  
Telephone: , phogan@icpgroup.com

### A/E' s REVIEW AND ACTION

- Substitution approved - Make submittals in accordance with Specification Substitution Procedures.
- Substitution approved as noted - Make submittals in accordance with Specification Substitution Procedures. *(see notes next page)*
- Substitution rejected - Use specified materials.
- Substitution Request received too late - Use specified materials.

Signed by: K. J. Schnadelbach Date: 1/23/23

Supporting Data Attached:  Drawings  Product Data  Samples  Tests  Reports  \_\_\_\_\_

## Notes:

1. Use textured white line paint.
2. Product line must have products equal to products listed in Section 02535, Part 2 - Products of Specification manual.
3. Products to be used on the project are to be submitted for final approval by landscape architect during construction process.
4. Construction procedure and number of surface coatings to meet or exceed requirements of Section 02535, Part 3 of Specification manual.
5. Final paint colors are to be U.S Open green and blue.
6. "Plexipave" and "DecoColor" by California Sports Surfaces are approved for this project subject to these notes.

K.J. Acknowledged 1/23/23